

# Enforcement Orders Signed October 30, 2018

## GUD 10671

**Company:** OXY INGLESIDE OIL PIPELINE, LLC

**Begin Date:** 12/23/2016

**End Date:** 09/13/2017

**Lead Inspector:** Bianca Gonzalez

**Phone Number:**

---

**System Name:** MAINLINE, 20"

**Evaluation:** 20170001

Item No	Requirement	Description	Location
1	Title16, 8.301 (a)(1)(B)	A written accident report (DOT Form 7000-1) was not filed with the Pipeline Safety Section within 30 days after discovery of a reportable crude oil incident.	System Wide
2	49 CFR 195.264(a)	The listed aboveground breakout tank(s) did not have a means for containing hazardous liquids in the event of spillage or tank failure.	Tank 975 and Tank 980

Penalty collected: \$7,500.00